

Tele: 23793509 /35763 (A)  
Fax : 23793541/23794549

**Policy Letter No 34 /2008**  
Directorate General Married  
Accommodation Project (DG MAP)  
Engineer-in-Chief's Branch,  
Integrated HQ of MoD (Army)  
Kashmir House, Rajaji Marg  
DHQPO, New Delhi-110011

21368/Elect/P&S/ 01 /MAP

14 Aug 2008

.....  
.....  
(DG MAP List A, B & C)

**PROVISION OF TAMPER PROOF ELECTRONIC METER**

1. Tampering of electronic meters is a common phenomenon being adopted by some of the users. This policy aims towards reduction of such incidents and thereby installing safety parameters to guard against electrical losses.
2. To avoid pilferage of electricity due to tampering and also to achieve better accuracy, the under mentioned electric single / three phase meters are to be provided in the DUs:-
  - (a) **For JCOs/OR Accommodation.** Tamper proof single phase 230 Volts AC Electronic Energy Meter of accuracy Class 1, digital type in polycarbonate body, conforming to IS: 13779 and CBIP Technical Report 88, of capacity 5-30 Amps & 10-40 Amps(for future requirement). Detailed specifications are attached as Appendix 'A'.
  - (b) **For Offrs Accommodation.** Tamper proof, three phase 4 wire 415 Volts AC Electronic Energy Meter of accuracy Class 1, digital type in polycarbonate body, conforming to IS: 13779 and CBIP Technical Report 88 of capacity 10-40 Amps and 15-60 Amps(for future requirement). Detailed specifications are attached as Appendix 'B'.
3. Executing Agencies and Planning Teams of DG MAP are requested to ensure provisioning of 'Tamper Proof Electronic Meter' in the project DPRs. For projects where DPRs are approved, provisioning may be ensured at tender stage. For projects where contracts have been concluded, changes shall be carried out on case-to-case basis, in close coordination with and prior approval of Planning Team of DG MAP.

(Sanjeev Gupta)  
Lt Col  
SO1 (Policy & Standardization)  
for DG MAP

Encl : As above

**Internal**

Plg Team 'A'

Plg Team 'B'

Contract Sec

- for information and necessary action please.